

NOTES

- CONTRACTOR IS RESPONSIBLE FOR PROVIDING PIPELINE DISINFECTION SERVICES OF A QUALIFIED SUBCONTRACTOR ACCEPTABLE TO THE CITY FNGINFER
- SUBCONTRACTOR SHALL USE DISINFECTION METHODS AND MATERIALS THAT MEET DOHS REQUIREMENTS FOR POTABLE WATER DISTRIBUTION SYSTEMS.
- RESIDUAL CHLORINE LEVELS AT THE START AND END OF THE DISINFECTION CONTACT TIME SHALL BE RECORDED BEFORE FLUSHING AND REFILLING.
- 4. SUBCONTRACTOR SHALL DISINFECT ALL WATER FLUSHED AND DISCHARGED PER RWQCB REQUIREMENTS.
- 5. CONTRACTOR WILL REFILL THE PIPELINE WITH POTABLE WATER AND NOTIFY THE CITY TO TAKE BAC-T SAMPLES FOR LAB ANALYSIS.
- CONTRACTORS SYSTEM CAN NOT BE PUT INTO SERVICE UNTIL LAB TESTS, CONFIRM THAT DOHS REQUIREMENTS ARE MET.
- WHEN CHLORINATION, AIR RELIEF, OR BLOW-OFF IS NO LONGER REQUIRED.
 THE GATE BOX, LID, RISER AND ASSEMBLY SHALL BE REMOVED LEAVING
 THE BRASS COUPLING AT THE CORPORATION STOP, WHICH WILL BE PLUGGED
 WITH A 2 INCH BRASS PLUG.

MATERIAL LIST

- (1)2" BRASS PLUG
- (2) 2" BRASS COUPLING
- (3) 2"x4" BRASS NIPPLE
- (4) 2" BRASS STREET ELL
- (5) 2" BRASS RISER AS REQUIRED
- (6) ADJUSTABLE 12" GATE BOX AND LID. SEE NOTE 7.
- (7) SPOT BRAZE
- (8)2" BRASS VALVE
- (9) 12" POLYVINYL CHLORIDE PIPE
- (10) 2" BALL VALVE
- (11) 2" "THREAD-O-LET"
- (12) 1 1/2"x2" CORPORATION STOP
- (13) PIPE SIZEx1 1/2" SERVICE SADDLE



APPROVED BY

JOHN P. SULLIVAN CITY ENGINEER

RECOMMENDED:

S7875 3/14/5

ASST. UTIL, DIRECTOR/ENG,

REV DESCRIPTION

BY APP'D DATE

CITY OF ONTARIO

TEMPORARY
DISINFECTION AIR
RELIEF OR BLOW-OFF
ASSEMBLY

STANDARD DRAWING NUMBER

4108