

NOTE

- CONTRACTOR SHALL TEST ALL PIPELINES AND APPURTENANCES @ 50 PSI OVER THE CLASS/RATING OF THE PIPE UNLESS OTHERWISE NOTED IN THE PROJECT PLANS AND SPECIFICATIONS.
- 2. LIMITS OF REMOVAL OF TEMPORARY FACILITIES ARE SUBJECT TO CITY APPROVAL.



(12) 3/4" VALVE & PRESSURE GAUGE (350 PSI) (13) 3/4" HIGH PRESSURE HOSE OR COPPER PIPE

(14) 3/4" BRASS TEES PRESSURE GAUGE AND VALVE

24079 4/1/5

OHN P. SULLIVAN CITY ENGINEER RCE DATE

RECOMMENDED:

437

57875 3/14/5

ASST. UTIL. DIRECTOR/ENG. RCE DATE

REV DESCRIPTION BY APP'D DATE

CITY OF ONTARIO

1" TEMPORARY
HYDROSTATIC
PIPELINE TESTING
INSTALLATION

STANDARD DRAWING NUMBER

4305