



DETAIL "A"

NOTES

- ROCK SIZES, UNLESS OTHERWISE SPECIFIED, SHALL BE COBBLESTONES, MAX. 12" TO MIN. 6", WITH ONE SIDE FLAT.
- MINIMUM OF 1/2 OF THE COBBLE THICKNESS SHALL BE EMBEDED IN 4" PEA GRAVEL CONCRETE BED.
- 3. ALL SPACES BETWEEN STONES SHALL BE FILLED WITH CLASS "D" MORTAR, 1 PART CEMENT TO 2 1/2 PARTS SAND, 2000 p.s.i. PORTLAND CEMENT CONCRETE. NO DRY PACK IS ALLOWED. FILL TO 2/3 HEIGHT OF ROCK. THE SURROUNDING CURB, SIDEWALK AND ASPHALT PAVEMENT SHALL BE PROTECTED FROM SPILLAGE.
- 4. A SAMPLE AREA, MIN. 10 SQ. FT., SHALL BE APPROVED BY THE CITY INSPECTOR PRIOR TO PROCEEDING WITH THE REMAINING ROCK WORK.
- FINAL RESTING POSITION OF ALL ROCKS SHALL BE APPROVED BY THE CITY INSPECTOR.
- 6. ROCKS SHALL BE SMOOTH, ROUNDED, FREE OF OBJECTIONABLE DISFIGURATIONS AND IRON CONTENT, AS APPROVED BY THE CITY INSPECTOR.
- 7. CONCRETE SHALL BE CLASS 520-D-2500.
- 8. AFTER CONCRETE MORTAR HAS SET, HYDRO BLAST OR ACID ETCH, AS DIRECTED BY THE CITY INSPECTOR. BRUSH ROCKS TO REMOVE CEMENT COATING.
- 9. THE 18" WIDE CONCRETE STRIP IS FOR MEDIANS 8' WIDE AND OVER.



APPROVED BY:

JOHN P. SULLIVAN CITY ENGINEER RCE DATE

RECOMMENDED:

JUM WWW. 33340 8/07/06

ASSISTANT CITY ENGINEER RCE DATE

REV DESCRIPTION BY APP'D DATE

CITY OF ONTARIO

ROCK MEDIAN

STANDARD DRAWING NUMBER

1215